FORM 8-J

Fire Pumps

Annual Test Summary Page

Date: _____ **Inspector:** _____ **System:** _____

Location: _____

	Test 1	Test 2	Test 3
Approximate percent of rated pump discharge (gpm)/(L/min)	0	100%	150%
Nozzle size in inches (mm)	No flow		
Pitot pressure in psi (bar)	None		
Flow in gpm (L/min)	None		
Pump suction in psi (bar)			
Pump discharge in psi (bar)			
Net pump head (discharge pressure minus suction pressure)			
Pump speed (rpm)			
Operate electric circuit breaker.			
Test emergency power supply.			
Check for excessive back pressure in exhaust system.			

Notes _____

Copyright © 2000 National Fire Protection Association